# Fisher<sup>™</sup> 377 Trip Valve


Fisher 377 pressure-sensing trip valves are for control applications where a specific valve/actuator action is required when supply pressure falls below a specific point. When supply pressure falls below the trip point (see figure 1), the trip valve causes the actuator to fail up, lock in the last position, or fail down. When the supply pressure rises above the trip point, the 377 trip valve automatically resets, allowing the system to return to normal operation. The trip valve can be top-mounted on a manifold, yoke-mounted, or bracket-mounted to match the application requirements. 377 trip valves can be used with Fisher 480, 585C, 685, 1061, 1066, 1069, and Bettis <sup>™</sup> G Series piston actuators.



W4292-1

# **Features**

- Cost Effective—Single trip valve construction reduces costs and spare part requirements of those systems using three separate switching valves to perform the failure functions. A single trip valve greatly simplifies piping requirements.
- Ease of Mode Conversion—Conversion to any of the fail modes requires only minor hookup changes.
- Adjustable Trip Valve—The trip point is adjustable for specific supply pressure requirements.
- Reliable Operation—The trip valve design includes large diaphragm areas and few moving parts for efficient performance, minimum maintenance, and long service life.



Fisher 377 Trip Valve Mounted on Size 130 585C Actuator





## Specifications

## **Available Configurations**

When supply pressure falls below the trip point,

377D Trip Valve: Fails actuator piston down. Includes check valve and volume tank.

**377L Trip Valve:** Locks actuator piston in the last position.

377U Trip Valve: Fails actuator piston up. Includes check valve and volume tank.

377CW Trip Valve: Fails fully clockwise to close the valve. Requires check valve and volume tank. Trip valve moves piston to either up/down position and requires actuator configuration for actual clockwise movement.

377CCW Trip Valve: Fails fully counterclockwise to close the valve. Requires check valve and volume tank. Trip valve moves piston to either up/down position and requires actuator configuration for actual counterclockwise movement.

All 377 trip valves can be converted to any of the above fail modes with minor hookup changes

## Allowable Supply Pressure for Trip Valve<sup>(1)</sup>

Maximum: 10.3 bar (150 psig) Minimum: 3.8 bar (55 psig)

### Outlet Pressure(1)

Normal Operation: Pressure from control device Fail-Up or Fail-Down Mode: Maximum volume tank pressure

Lock-In-Last-Position: Respective cylinder pressure

### Trip Point(2)

Adjustable from a minimum of 2.8 bar (40 psig) to a maximum of 72 percent of supply pressure; see figure 1

Reset: 12.5 to 33 percent above adjusted trip point

## Flow Coefficients $(C_v)^{(3)}$

Depends on flow path (shown in figure 3) as follows:

Port A to Port B and Port D to Port E: 0.5 Port B to Port C and Port E to Port F: 0.6

## **Body Connections**

1/4 NPT internal

### Temperature Capabilities<sup>(1)</sup>

Nitrile Diaphragms and O-Rings: -40 to 82°C (-40 to 180°F)

Fluorocarbon Diaphragms and O-Rings: -18 to 104°C (0 to 220°F)

# Volume Tank Maximum Internal Working Pressure (for 377D, 377U, 377CW and 377CCW trip valves)

**Standard:** 10.3 bar (150 psig) for non-ASME approved applications<sup>(4)</sup>

ASME Approved Applications: Rated 10.3 bar (150 psiq), maximum; 9.3 bar (135 psiq), recommended

#### **Volume Tank Sizing**

See sizing section

#### **Hazardous Area Classification**

Complies with the requirements of ATEX Group II Category 2 Gas and Dust



377 SST

Safety Instrumented System Classification SIL 3 capable - certified by exida Consulting LLC

-Continued-

## **Table of Contents**

Features	1
Safety Certification	
Principle of Operation	4
377D Trip Valve	
377L Trip Valve	6
377U Trip Valve	7
377CW and 377 CCW Trip Valves	7

Volume Tank Sizing	 	 	. 8
Ordering Information			
Application			
Trip Valve	 	 	10

## Specifications (continued)

### Mounting

Top-Mounted: Manifold-mounted between a 3570 positioner and a 480 actuator (manifolds cannot be supplied with 585C, 685, 1061, 1066, and 1069 piston actuators)

Side-Mounted: Yoke-mounted or bracket-mounted for use with a FIELDVUE™ DVC6200. DVC6200f. DVC6200p, DVC6000, or DVC6000f digital valve controller

### **Approximate Weight**

### Trip Valve

Aluminum: 0.95 kg (2.1 pounds) Stainless Steel: 2.31 kg (5.1 pounds) Mounting Manifold: 0.5 kg (1.2 pounds) Volume Tank: Varies between 5.4 and 363 kg (12 and 800 pounds) depending on size

#### **Construction Materials**

**Housing:** ■ Aluminum or ■ Stainless steel Cover: 25% mineral-filled thermoplastic polyester

O-Rings: Nitrile or fluorocarbon Diaphragms: Nitrile or fluorocarbon


Interior parts

Aluminum construction: Brass, aluminum, steel, and

stainless steel

Stainless Steel construction: Stainless steel

Figure 1. Maximum Trip Point Settings



<sup>1</sup> Trip point may be set to any value between 2.8 bar (40 psig) and the maximum trip point line.

# Safety Certification

The 377 SST is certified for use in Safety Instrumented System (SIS) applications. Certification is by exida Consulting LLC, a global provider of functional safety and control system security (see figure 2). SIS certification is identified on the product by a label affixed to the pilot body.

The functional safety assessment was performed to the requirements of IEC 61508: ed2, 2010, SIL3 for mechanical components.

Figure 2. exida Certificate



<sup>1.</sup> The pressure/temperature limits in this document and any applicable standard or code limitation should not be exceeded.
2. If the trip point is not specified, the trip point is factory-set at 72 percent of supply pressure or 2.8 bar (40 psig), whichever is higher.
3. Values represent nominal Cy measures for each port pair using a trip valve/actuator combination.
4. This tank is rated at 14.5 bar (240 psig) in LP service. When used with air, the rating should be considered to be 10.3 bar (150 psig), consistent with the maximum pressure allowed for the 377 trip valve.

<sup>2</sup> Reset occurs a 12.5 to 33 percent above adjusted trip point.

# **Principle of Operation**

# 377D Trip Valve


In normal operation, supply pressure loads the upper diaphragm (see figure 3) of the unit. The valve plug spring keeps the exhaust port closed. Supply pressure also loads the lower diaphragm through the restriction, causing the plug assemblies to move down and isolate ports C and F while connecting port A to B and port D to E.

Normal actuator control pressure flows from the control device to the top of the cylinder through ports A and B and to the bottom of the cylinder through ports D and E. A volume tank is charged to maximum supply pressure through a check valve in order to retain maximum supply pressure in the volume tank if supply pressure drops.

When supply pressure falls below the trip point pressure in the fail-down mode (see figure 4), the exhaust port opens, venting the supply pressure that is loading the lower diaphragm. This causes the upper ports of the plug assemblies to close and shut off normal pressure flow from the control device to the actuator.

Volume tank pressure then flows through ports C and B to the top of the actuator cylinder, while pressure in the bottom of the actuator cylinder is vented through ports E and F. The pressure imbalance created forces the actuator piston down.

Figure 3. Simplified Sectional View of Trip Valve



When supply pressure is restored, it loads the upper and lower diaphragms, causing the trip valve to reset. The exhaust port closes. The upper ports of the plug assemblies open, and the lower ports close. Normal actuator control pressure flow from the control device is restored through ports A and B and ports D and E. The check valve opens and recharges the volume tank to the maximum supply pressure.

Figure 4. Fisher 377D Trip Valve Shown Tripped





Figure 5. Fisher 377L Trip Valve Shown Tripped




# 377L Trip Valve

When supply pressure falls below the trip point in the lock-in-last-position mode (see figure 5), the exhaust port opens, venting supply pressure from the lower diaphragm. This causes the upper ports of the plug assemblies to close and the lower ports to open. Since ports C and F are plugged, no pressure change occurs

on either side of the actuator piston, and the piston is pressure-locked in position upon loss of supply pressure. No volume tank is necessary in this mode. When supply pressure is restored, the plug assemblies move back into the normal operating position, and supply pressure flows from the control device through ports A and B to the actuator.

Figure 6. Fisher 377U Trip Valve Shown Tripped



# 377U Trip Valve

The fail-up mode of operation (figure 6) is similar to the fail-down mode of operation except that connections to port C and F are reversed. When supply pressure falls below the trip point, the top of the actuator cylinder vents, and volume tank pressure loads the bottom of the actuator cylinder. The pressure imbalance created forces the actuator piston up.

# 377CW and 377CCW Trip Valves

Makes use of the 377D or 377U trip valve configurations, a piston actuator, and volume tank with check valve to move the piston actuator to either the up or down position. Requires the actuator and valve configuration for actual clockwise or counterclockwise movement.

62.3:377 September 2017


# Volume Tank Sizing

#### Note

State and local regulations may require the use of ASME-approved volume tanks. It is the user's responsibility to determine requirements and applicable regulations for proper volume tank selection.

Several different tanks of varying capacities are available. The volume tank must be selected so that its pressure at any time is greater than the minimum percentage of maximum supply pressure required to stroke the actuator (see figure 7).

Figure 7. Volume Tank Sizing Graph



MINIMUM FAILURE POSITIONING PERCENTAGE, Y

1. Size the volume tank as indicated below:

For Actuators on Sliding Stem For Actuators on Rotary-Shaft Valves, Determine: Valves, Determine:  $Y = F/AP \times 100$  $Y = P_r/P \times 100$ 

#### Where:

Y = Minimum failure positioning percentage F = Actuator thrust required in normal operation to position the valve at the desired limit of travel A = Effective piston area (from the appropriate actuator bulletin)

P = Maximum supply pressure available  $P_r$  = Highest pressure required by the actuator to stroke the valve (from the appropriate actuator sizing technique)

2. With the minimum failure positioning percentage obtained in step 1, enter the value on the abscissa of the graph in figure 7. Locate the corresponding point on the curve, and read across to find the volume ratio, R.

#### 3. Determine:

$$V_T = (XA)/R$$

#### Where:

X = Maximum actuator travel from the appropriate actuator bulletin. For rotary actuators, substitute total displacement (XA). Actuator displacement can be found in the product bulletin, or contact your Emerson sales office or Local Business Partner.  $V_T$  = Minimum volume tank size required R = Volume ratio from step 2

# Installation

The 377 trip valve may be mounted in any position without affecting normal operation. Dimensions are shown in figure 8 and tables 1 and 2.


Table 1. Standard Volume Tank Dimensions

Tank Volume			J	L	
Liters	Inch <sup>3</sup> /Gal	mm	Inches	mm	Inches
11.8	721/3.1	309	12.16	318	12.5
21.6	1315/5.7	310	12.19	451	17.75
32.3	1970/8.5	309	12.16	595	23.43
42.9	2615/11.3	309	12.16	737	29.00
65.6	4001/17.3	309	12.16	1095	43.12
131.1	8002/34.6	Requires two 65.6 liter (4001 inch <sup>3</sup> / 17.3 gal) volume tanks			

Table 2. ASME-Approved, Canadian Registered Volume Tank Dimensions

Tar	Tank Volume		J		L
Liters	Inch <sup>3</sup> /Gal	mm Inches		mm	Inches
8.5	518/2.2	208	8.19	337	13.25
24.9	1520/6.6	305	12	427	16.81
30	1831/7.9	254	10	684	26.94
42.8	2609/11.3	305	12	681	26.81
68.8	4199/18.1	360	14.19	792	31.19
71.6	4371/18.9	305	12	1087	42.81
143.3	8742/37.86	Requires two 71.6 liter (4371 inch <sup>3</sup> / 18.9 gal volume tanks			
114	6930/30	406	16	965	38
227	13860/60	508	20	1219	48
303	18480/80	610	24	1600	63
454	27720/120	610	24	1702	67
908	55440/240	762	30	2134	87

Figure 8. Dimensions of Trip Valve with Manifold (also see tables 1 and 2)



1 Refer to table 1 and 2 for J and L dimensions

# **Ordering Information**

When ordering specify:

# **Application**

- 1. Available supply pressure
- 2. Actuator type number and size
- 3. Aluminum or stainless steel construction
- 4. Input signal range
- 5. Operating ambient temperature
- 6. Trip point (If the trip point is not specified, the unit is factory-set to trip at 72 percent of supply pressure or 2.8 bar (40 psig), whichever is higher.)
- 7. Volume tank size

## **Trip Valve**

Refer to the specifications. Review the information under each specification and in the referenced figures. Specify the desired choice wherever there is a selection to be made. Be sure to specify the type number as described in the Available Configurations specification.

Refer to table 3 for guidelines on specifying the correct trip valve.

Table 3. Guidelines for Specifying Fisher 377 Trip Valve

Actuator Type	Fail Mode	Valve Action <sup>(1)</sup>	Trip Valve	
Sliding-Stem	Fail Open	PDTC	377U	
	Fail Open	PDTO	377D	
	Fail Closed	PDTC	377D	
	Fall Closed	PDTO	377U	
Rotary: 1035 Bettis G Series	Fully Clockwise	Clockwise	377CW	
	Fully Counterclockwise	to Close	377CCW	
Rotary: 1069	Fully Clockwise		377CW	
	Fully Counterclockwise		377CCW	
1. PDTC—Push Down to Close; PDTO—Push Down to Open				

Neither Emerson, Emerson Automation Solutions, nor any of their affiliated entities assumes responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use, and maintenance of any product remains solely with the purchaser and end user.

Fisher and FIELDVUE are marks owned by one of the companies in the Emerson Automation Solutions business unit of Emerson Electric Co. Emerson Automation Solutions, Emerson, and the Emerson logo are trademarks and service marks of Emerson Electric Co. All other marks are the property of their respective owners.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. All sales are governed by our terms and conditions, which are available upon request. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Emerson Automation Solutions Marshalltown, Iowa 50158 USA Sorocaba, 18087 Brazil Cernay 68700 France Dubai, United Arab Emirates Singapore 128461 Singapore

www.Fisher.com

